## **Power Manager and Renewables**

A Low Friction Approach





## **Duke Energy**

One of the LARGEST energy holding companies in the U.S.



8.2 MILLION

Retail electric customers in six states



Natural gas customers in five states



Headquarters: Charlotte, N.C.



We own and operate diverse power generation assets in North America, including a portfolio of natural gas, coal, renewable wind, solar, energy storage, nuclear, hydro and microgrid projects.

11,900 megawatts (MW) including 6,651 MW regulated and 5,279 MW commercial wind and solar owned, operated or contracted with an updated goal of 30,000 MW wind and solar by 2035.\*\*


# \$145+ BILLION CAPITAL PLAN

85% (\$123 billion) funding investments in the grid and our clean energy transition.

<sup>\* 27,859</sup> employees as of December 31, 2022.

<sup>\*\*</sup> Includes owned and contracted within our regulated jurisdictions.

## Here Comes the Sun – I say!\*



\*thank you George Harrison

## The Challenge



How can we utilize our direct load control option to reduce load when electricity demand is still high and renewable supply is waning? To help:

- Avoid the cost of bringing additional generation online
- While maintaining customer satisfaction, despite potentially: more frequent events, done later in the day and with longer durations

## The Approach – "Low Friction" Cycling Options

### **Current Options**

- 100% full shed
- 64% and 50% TrueCycle
  - Reduce expected compressor runtime by 64% and 50%

### Future Steps

- Learn from the ~250,000 customers (301,000 ACs) on our DLC program in the Duke Energy Carolinas jurisdiction
- Add TrueCycle Strategies below 50%
- Conduct EM&V tests this summer with new strategies
- Resource Innovations (evaluator) use test results to create a new Time/Temperature Matrix for estimating load reduction capabilities
- Utilize the TTM to determine which strategy to use to meet the load reduction needs with the least impact to our customers


## How much load might we reduce?

## Duke Energy Carolinas - Power Manager AC Switch April 2023 Time Temperature Matrix - Maximum Event Period Temperature

Inputs									
Dispatch Type	Normal Dispatch								
Event Start Time	6 PM								
Event Duration	2								
Event Period Max Temp	90								
# Customers	249,100								

Event Window Average Impacts										
Load without DR	3.89 kW per customer									
Load with DR	3.17 kW per customer									
Impact per Customer	-0.72 kW per customer									
Program Impact	-191.7 MW									
% Impact	-18.5 %									

Line Loss (gross up to Generator) 1.067359



mpact @ Gen
64% Cycle
-191.7 MW
50% Cycle
-149.7 MW
40% Cycle
-119.8 MW
35% Cycle
-104.8 MW
30% Cycle
-89.8 MW
25% Cycle
-74.9 MW
20% Cycle
-59.9 MW
15% Cycle
-44.9 MW
10% Cycle
-29.9 MW

### What about "low friction" and customer satisfaction?

#### Current

		Control Strategy								
		10	0%	64	1%	50%				
Forecast Av	/g. Minutes	Closed	Open	Closed	Open	Closed	Open			
Running	Off	Relay	Relay	Relay	Relay	Relay	Relay			
30	0	0	30	10.8	19.2	15	15			
25	5	0	30	9	21	12.5	17.5			
20	10	0	30	7.5	22.5	10	20			
15	15	0	30	7.5	22.5	7.5	22.5			
10	20	0	30	7.5	22.5	7.5	22.5			
5	25	0	30	7.5	22.5	7.5	22.5			

#### Future

		Possible Future Control Srategies - all to be tested in 2023 EM&V Study													
		40	)%	35%		30%		25%		20%		15%		10%	
Forecast Avg. Minutes		Closed	Open	Closed	Open	Closed	Open	Closed	Open	Closed	Open	Closed	Open	Closed	Open
Running	Off	Relay	Relay	Relay	Relay	Relay	Relay	Relay	Relay	Relay	Relay	Relay	Relay	Relay	Relay
30	0	18	12	19.5	10.5	21	9	22.5	7.5	24	6	25.5	4.5	27	3
25	5	15	15	16.25	13.75	17.5	12.5	18.75	11.25	20	10	21.25	8.75	22.5	7.5
20	10	12	18	13	17	14	16	15	15	16	14	17	13	18	12
15	15	9	21	9.75	20.25	10.5	19.5	11.25	18.75	12	18	12.75	17.25	13.5	16.5
10	20	7.5	22.5	7.5	22.5	7.5	22.5	7.5	22.5	8	22	8.5	21.5	9	21
5	25	7.5	22.5	7.5	22.5	7.5	22.5	7.5	22.5	7.5	22.5	7.5	22.5	7.5	22.5

Closed Relay = Allows AC to run, if needed.

Open Relay = Prevents AC from running.

### 2022 - Two late season low friction events

### August 31, Wednesday

- 15% Cycling from 4:00 to 6:00 pm, system average temp 88.5°
- Lessons learned:
  - We used "no ramp-in", but some customers (Gen1 LCR4700) were controlled for much of or all the first 30 minutes. Going forward, we will not use the "no-ramp" option.
  - Continuing use of a ramp-out TBD.
  - Increase to 20 calls vs 2 (prior day) and 3 (day after) calls to our event hotline\* number after 4:00 pm.

### September 6, Tuesday

- 25% Cycling from 5:00 to 7:00 pm, average temp 84°
- A few pop-up showers in the service area brought down the temp from 87° HE 5:00 pm.
- 4 pm+ hotline\* calls: 7 and 10 pre and post days, 14 event day
- Per Franklin Energy manager: "It was like it never happened."

<sup>\*</sup>compared to 558 on the last non-friction event (50% cycling, 4 - 6 pm, 95°)

### Thank you!



BUILDING A SMARTER ENERGY FUTURE ®