



Speaker Introductions



Mikaela Mohaupt, North American Sales Specialist, CYME




Rena Wang, Customer Training
Manager



Michael Sharp, AMI Product Manager



Brightlayer Utilities suite - End-to-End utility focus




Powerina Business Worldwide

AMI/Yukon Reporting Capabilities



Device Definitions - Attributes






Device Definitions - Attributes

 Home / Support / Device Definitions ★ Device Definitions **Filters Device Type Display Group Change Group** (none) (none) (none) RFN-410fD Tag RFN-420fL (none) RFN-420fX RFN-420fD RFN-420fRX RFN-420fRD RFN-410cL RFN-420cL RFN-420cD WRL-420cL WRL-420cD RFN-430A3D RFN-430A3T RFN-430A3K RFN-430A3R RFN-430KV RENI-430SL0




Example: RFN-420cD Device Attributes



- Common Attributes for Reporting:
 - Voltage (OV/UV)
 - Blink Count
 - Delivered kW (for Total kW calculations)
 - Outage Count



Yukon Reports: Dashboard - Actions Widget




*Phase Detect is a legacy PLC report



Actions Widget – Aggregate Interval Data Report


- Report of a calculated, aggregate point of a Device Group or individual device
 - Can be used in place of Virtual Device
- Use Cases:
 - Total kW over a period of time
 - Load Shed comparisons
 - Time of Use






Actions Widget – Archive Data Analysis

- Report of any archived data for individual or group of devices
 - Also found under Collection Actions
- Use Cases:
 - Voltage Profile
 - Usage Data






Yukon Reports: Reports





Yukon Reports: Reports






Yukon Reports: Data Export

- "Traditionally" used for billing files
- Allows export of any Data Attribute from Yukon
 - Configurable export format depending on third-party software







Data Export Example: Blink Count Report

Α	A B		D	Е	
Device Name	Meter	Date	Time	Blink Count	
Device Name1	Meter1	4/10/2023	19:08:57	4	
Device Name2	Meter2	4/10/2023	19:08:55	22	
Device Name3	Meter3				
Device Name4	Meter4				
Device Name5	Meter5				
Device Name6	Meter6	4/10/2023	19:08:55	512	
Device Name7	Meter7	4/10/2023	14:08:55	2	



Data Export Example: Voltage Report

	Α	В	С	D	E	F	G	Н	I	J
1	Device Name	Meter Number	MinVolt Date	MinVolt Time	MinVolt Value	MaxVolt Date	MaxVolt Time	MaxVolt Value	Pk Dmd	
2	Device Name70	Meter Number70	3/3/2023	16:00:00	236	3/10/2023	18:00:00	246	3/22/2023	6.06
3	Device Name71	Meter Number71	3/27/2023	11:00:00	242	2/27/2023	1:00:00	248	3/8/2023	7.77
4	Device Name72	Meter Number72	3/3/2023	19:00:00	227	3/23/2023	2:00:00	242	3/6/2023	7.53
5	Device Name73	Meter Number73	3/14/2023	9:00:00	238	3/27/2023	7:00:00	245	3/1/2023	3.22
6	Device Name74	Meter Number74	3/14/2023	16:00:00	231	3/5/2023	21:00:00	245	3/12/2023	14.42
7	Device Name75	Meter Number75	3/11/2023	11:00:00	240	3/23/2023	2:00:00	245	3/21/2023	3.51
8	Device Name76	Meter Number76	2/26/2023	21:00:00	231	3/23/2023	2:00:00	244	2/27/2023	0
9	Device Name77	Meter Number77	3/12/2023	14:00:00	238	3/23/2023	2:00:00	246	3/11/2023	5.49
10	Device Name78	Meter Number78	2/28/2023	19:00:00	239	3/7/2023	8:00:00	245	2/28/2023	6.98
11	Device Name79	Meter Number79	3/25/2023	10:00:00	241	3/27/2023	1:00:00	246	3/10/2023	6.92
12	Device Name80	Meter Number80	3/27/2023	12:00:00	230	2/27/2023	1:00:00	241	3/19/2023	7.37
13	Device Name81	Meter Number81	3/6/2023	11:00:00	236	3/7/2023	8:00:00	244	3/21/2023	3.57
14	Device Name82	Meter Number82	3/20/2023	10:00:00	239	3/26/2023	1:00:00	247	3/3/2023	5.56
15	Device Name83	Meter Number83	3/4/2023	6:00:00	239	3/4/2023	3:00:00	244	3/19/2023	6.93
16	Device Name84	Meter Number84	3/3/2023	10:00:00	234	3/23/2023	2:00:00	243	3/28/2023	6.98
17	Device Name85	Meter Number85	3/27/2023	8:00:00	242	3/15/2023	15:00:00	248	3/13/2023	5.76
18	Device Name86	Meter Number86	2/27/2023	20:00:00	238	3/26/2023	0:00:00	246	3/7/2023	8.25
19	Device Name87	Meter Number87	3/12/2023	11:00:00	238	2/27/2023	15:00:00	244	3/18/2023	7.91
20	Device Name88	Meter Number88	3/13/2023	20:00:00	242	3/27/2023	15:00:00	245	3/25/2023	5.43
21	Device Name89	Meter Number89	3/27/2023	17:00:00	240	3/15/2023	17:00:00	245	3/22/2023	10.08
22	Device Name90	Meter Number90	3/14/2023	9:00:00	238	3/23/2023	2:00:00	244	3/4/2023	2.05
23	Device Name91	Meter Number91	2/27/2023	6:00:00	238	3/23/2023	23:00:00	246	3/25/2023	10.73
24	Device Name92	Meter Number92	3/20/2023	12:00:00	233	3/23/2023	2:00:00	243	2/27/2023	8.96
25	D . M 03	M . N . L 02	2/27/2022	40.00.00	244	2/27/2022	4 00 00	240	2/42/2022	2.64







CYME – Advanced Distribution Planning Software














Best-in-Class System Analysis Tools and Services From Transmission to Distribution to Industrial




AMI to CYME – How?

How do we take this info:

4	Α	В	С	D	E	F
1	Device Name	Meter Number	MinVolt Date	MinVolt Time	MinVolt Value	MaxVolt Date
2	Device Name70	Meter Number70	3/3/2023	16:00:00	236	3/10/2023
3	Device Name71	Meter Number71	3/27/2023	11:00:00	242	2/27/2023
4	Device Name72	Meter Number72	3/3/2023	19:00:00	227	3/23/2023
5	Device Name73	Meter Number73	3/14/2023	9:00:00	238	3/27/2023
6	Device Name74	Meter Number74	3/14/2023	16:00:00	231	3/5/2023
7	Device Name75	Meter Number75	3/11/2023	11:00:00	240	3/23/2023
8	Device Name76	Meter Number76	2/26/2023	21:00:00	231	3/23/2023
9	Device Name77	Meter Number77	3/12/2023	14:00:00	238	3/23/2023
10	Device Name78	Meter Number78	2/28/2023	19:00:00	239	3/7/2023
11	Device Name79	Meter Number79	3/25/2023	10:00:00	241	3/27/2023
12	Device Name80	Meter Number80	3/27/2023	12:00:00	230	2/27/2023
13	Device Name81	Meter Number81	3/6/2023	11:00:00	236	3/7/2023
14	Device Name82	Meter Number82	3/20/2023	10:00:00	239	3/26/2023
15	Device Name83	Meter Number83	3/4/2023	6:00:00	239	3/4/2023
16	Device Name84	Meter Number84	3/3/2023	10:00:00	234	3/23/2023
17	Device Name85	Meter Number85	3/27/2023	8:00:00	242	3/15/2023
18	Device Name86	Meter Number86	2/27/2023	20:00:00	238	3/26/2023
19	Device Name87	Meter Number87	3/12/2023	11:00:00	238	2/27/2023
20	Device Name88	Meter Number88	3/13/2023	20:00:00	242	3/27/2023
21	Device Name89	Meter Number89	3/27/2023	17:00:00	240	3/15/2023
22	Device Name90	Meter Number90	3/14/2023	9:00:00	238	3/23/2023
23	Device Name91	Meter Number91	2/27/2023	6:00:00	238	3/23/2023

Import it here:



And then what can we do with it in CYME?



AMI to CYME – Method #1


CYME Gateway

- The Gateway product was originally created to automatically update the CYME network using GIS data.
- Today, our engineering team can also import OMS, SCADA and AMI data into CYME with the GIS data.
- If a customer does not have a Gateway, AMI can be included in the development of the customer's Gateway to be imported with the GIS data.
- If a customer already has a Gateway for GIS data, but no AMI data, then AMI can be added on.
 - Smaller project than creating a new Gateway.
 - New project and terms to be adjusted with this addition.



AMI to CYME – Method #2

- CYME is vendor agnostic and does not align to any single vendor for AMI or any other equipment data type.
- Customer can code data internally to format it into a usable format for CYME.
- The right shows a small sample from some data used for demonstrations.
- This uses Microsoft
 Access for databases but
 Oracle and SQL can be
 used instead.






AMI to CYME – Method #3

- Dynamic Data Pull Plugin
 - Updates network with time-based dynamic data
 - Creates a link between CYME and external systems where dynamic data reside, such as data historian, AMI/MDMS and forecasting tool.
 - Allows pulling data to CYME from a click of a button.
 - What type of data is concerned?
 - Power, current and/or voltage (meter)
 - Load and/or generation
 - Device statuses



Live Demonstration of CYME






Load Flow with Profile - Results

Report	S									
=	Search	▼ 🔍 🖫								
	△ Device Number	Device type	Phase	Nominal Capacity	Network Id	Overload count	Total overload time (hours)	Longest overload time (hours)	Worst loading (%)	Date and time of first overload
16	700316948	Overhead By Phase	ABC	224.0 A	EDNEYVILLE_RET_65171204	1	2.00	2.00	105.13	1/8/2021 6:00 PM
17	257688974	Overhead By Phase	ABC	224.0 A	EDNEYVILLE_RET_65171204	1	2.00	2.00	105.13	1/8/2021 6:00 PM
18	257688984	Overhead By Phase	ABC	224.0 A	EDNEYVILLE_RET_65171204	1	2.00	2.00	105.13	1/8/2021 6:00 PM
19	257688989	Overhead By Phase	ABC	224.0 A	EDNEYVILLE_RET_65171204	1	2.00	2.00	105.13	1/8/2021 6:00 PM
20	257688994	Overhead By Phase	ABC	224.0 A	EDNEYVILLE_RET_65171204	1	2.00	2.00	105.13	1/8/2021 6:00 PM
21	EDNEYVILLE_RET_6517120X	Source	ABC	30100.0 kVA	EDNEYVILLE_RET_6517120X	1	2.00	2.00	106.05	1/8/2021 6:00 PM
22	257695451	Overhead By Phase	A	129.0 A	EDNEYVILLE_RET_65171204	1	2.00	2.00	106.26	1/8/2021 6:00 PM
23	257695901	Overhead By Phase	C	129.0 A	EDNEYVILLE_RET_65171204	1	2.00	2.00	106.53	1/8/2021 6:00 PM
24	259513559	Overhead By Phase	C	170.0 A	EDNEYVILLE_RET_65171204	3	5.00	2.00	106.94	1/8/2021 11:00 AM
25	INNOVATIVE.SOLAR.16	Two-Winding Transformer	ABC	2000.0 kVA	EDNEYVILLE_RET_65171204	3	24.00	24.00	107.41	1/8/2021 1:00 AM
26	257691958	Overhead By Phase	С	170.0 A	EDNEYVILLE_RET_65171204	3	5.00	2.00	108.75	1/8/2021 11:00 AM
27	257695386	Overhead By Phase	С	129.0 A	EDNEYVILLE_RET_65171204	1	2.00	2.00	108.99	1/8/2021 6:00 PM
28	259512137	Overhead By Phase	С	129.0 A	EDNEYVILLE_RET_65171204	1	2.00	2.00	108.99	1/8/2021 6:00 PM
29	257695441	Overhead By Phase	A	129.0 A	EDNEYVILLE_RET_65171204	1	2.00	2.00	109.84	1/8/2021 6:00 PM
30	259513184	Overhead By Phase	С	170.0 A	EDNEYVILLE_RET_65171204	3	7.00	5.00	110.23	1/8/2021 11:00 AM
31	257691913	Overhead By Phase	С	170.0 A	EDNEYVILLE_RET_65171204	3	7.00	5.00	110.23	1/8/2021 11:00 AM
32	257692705	Overhead By Phase	ABC	170.0 A	EDNEYVILLE_RET_65171204	1	3.00	3.00	110.67	1/8/2021 6:00 PM
33	257692715	Overhead By Phase	ABC	170.0 A	EDNEYVILLE_RET_65171204	1	3.00	3.00	110.67	1/8/2021 6:00 PM
34	257692725	Overhead By Phase	ABC	170.0 A	EDNEYVILLE_RET_65171204	1	3.00	3.00	110.67	1/8/2021 6:00 PM
35	257695421	Overhead By Phase	A	129.0 A	EDNEYVILLE_RET_65171204	1	3.00	3.00	111.76	1/8/2021 6:00 PM
36	257692545	Overhead By Phase	ABC	170.0 A	EDNEYVILLE_RET_65171204	1	3.00	3.00	112.34	1/8/2021 6:00 PM
37	259573430	Overhead By Phase	ABC	170.0 A	EDNEYVILLE_RET_65171204	1	3.00	3.00	112.34	1/8/2021 6:00 PM
38	257692700	Overhead By Phase	ABC	170.0 A	EDNEYVILLE_RET_65171204	1	3.00	3.00	112.34	1/8/2021 6:00 PM
39	257689362	Overhead By Phase	ABC	480.0 A	EDNEYVILLE_RET_65171204	1	3.00	3.00	113.15	1/8/2021 6:00 PM
40	257689372	Overhead By Phase	ABC	480.0 A	EDNEYVILLE_RET_65171204	1	3.00	3.00	113.15	1/8/2021 6:00 PM
41	257689377	Overhead By Phase	ABC	480.0 A	EDNEYVILLE_RET_65171204	1	3.00	3.00	113.15	1/8/2021 6:00 PM
42	259225518	Overhead By Phase	ABC	480.0 A	EDNEYVILLE_RET_65171204	1	3.00	3.00	113.15	1/8/2021 6:00 PM
43	257689355	Overhead By Phase	ABC		EDNEYVILLE_RET_65171204	1	3.00	3.00	115.55	1/8/2021 6:00 PM
~	Load Flow with Profiles -	BESS Usage Summary	Load Flow with	Profiles - Device Abn	ormal Loading Summary 🛛 🗙	Load Flow with Pr	ofiles - Network Losses	Report Load Flow wit	h Profiles - Abnorm	al Voltage Summary



Load Flow with Profile - Results





Load Relief DER Optimization - Results

BESS Sizing Requirements							
Rated Storage Energy	500.0 kWh						
Max Discharging Power	300.0 kW						
Max Charging Power	300.0 kW						

			At Peak Power (Discharging)					At Minimum Power (Charging)					
Node ID	Score	Base Case Overload Count	Base Case Over-Voltage Count	New Over-Voltage Count	Base Case Under-Voltage Count	New Under-Voltage Count	Base Case Overload Count	Base Case Over-Voltage Count	New Over-Voltage Count	Base Case Under-Voltage Count	New Under-Voltage Count		
ase Case (without new DER)	0.0	133	188		662		3	679		0			
57692891	100.0	133	188	0	656	0	3	679	0	0	0	Apply	
57693122	100.0	133	188	0	656	0	3	679	0	0	0	Apply	
57693077	100.0	133	188	0	656	0	3	679	0	0	0	Apply	
57692915	100.0	133	188	0	656	0	3	679	0	0	0	Apply	
57692707	100.0	133	188	0	656	0	3	679	0	0	0	Apply	
7692898	100.0	133	188	0	656	0	3	679	0	0	0	Apply	
57692857	100.0	133	188	0	656	0	3	679	0	0	0	Apply	




Load Flow w/ Profiles Results After LRO

Reports										
≡ s	earch	· Q 强								
4	Device Number	Device type	Phase	Nominal Capacity	Network Id	Overload count	Total overload time (hours)	Longest overload time (hours)	Worst loading (%)	Date and time of first overload
1	257692705	Overhead By Phase	ABC	170.0 A	EDNEYVILLE_RET_65171204	1	2.00	2.00	100.11	1/8/2021 6:00 PM
2	257692715	Overhead By Phase	ABC	170.0 A	EDNEYVILLE_RET_65171204	1	2.00	2.00	100.11	1/8/2021 6:00 PM
3	257692725	Overhead By Phase	ABC	170.0 A	EDNEYVILLE_RET_65171204	1	2.00	2.00	100.11	1/8/2021 6:00 PM
4	257695456	Overhead By Phase	A	129.0 A	EDNEYVILLE_RET_65171204	1	1.00	1.00	100.86	1/8/2021 6:00 PM
5	257691963	Overhead By Phase	C	170.0 A	EDNEYVILLE_RET_65171204	1	1.00	1.00	101.37	1/8/2021 6:00 PM
6	700805362	Overhead By Phase	ABC	224.0 A	EDNEYVILLE_RET_65171204	1	1.00	1.00	101.42	1/8/2021 6:00 PM
7	700805363	Overhead By Phase	ABC	224.0 A	EDNEYVILLE_RET_65171204	1	1.00	1.00	101.42	1/8/2021 6:00 PM
8	705479522	Overhead By Phase	ABC	224.0 A	EDNEYVILLE_RET_65171204	1	1.00	1.00	101.42	1/8/2021 6:00 PM
9	257692545	Overhead By Phase	ABC	170.0 A	EDNEYVILLE_RET_65171204	2	3.00	3.00	101.85	1/8/2021 6:00 PM
10	259573430	Overhead By Phase	ABC	170.0 A	EDNEYVILLE_RET_65171204	2	3.00	3.00	101.85	1/8/2021 6:00 PM
11	257692700	Overhead By Phase	ABC	170.0 A	EDNEYVILLE_RET_65171204	1	3.00	3.00	101.85	1/8/2021 6:00 PM
12	259513564	Overhead By Phase	С	170.0 A	EDNEYVILLE_RET_65171204	1	2.00	2.00	102.66	1/8/2021 6:00 PM
13	EDNEYVILLE_RET_6517120X	Source	ABC	30100.0 kVA	EDNEYVILLE_RET_6517120X	1	3.00	3.00	103.95	1/8/2021 6:00 PM
14	700316925	Overhead By Phase	ABC	224.0 A	EDNEYVILLE_RET_65171204	1	2.00	2.00	104.85	1/8/2021 6:00 PM
15	700316921	Overhead By Phase	ABC	224.0 A	EDNEYVILLE_RET_65171204	1	2.00	2.00	104.85	1/8/2021 6:00 PM
16	700316927	Overhead By Phase	ABC	224.0 A	EDNEYVILLE_RET_65171204	1	2.00	2.00	104.85	1/8/2021 6:00 PM
17	700316948	Overhead By Phase	ABC	224.0 A	EDNEYVILLE_RET_65171204	1	2.00	2.00	104.85	1/8/2021 6:00 PM
18	257688974	Overhead By Phase	ABC	224.0 A	EDNEYVILLE_RET_65171204	1	2.00	2.00	104.85	1/8/2021 6:00 PM
19	257688984	Overhead By Phase	ABC	224.0 A	EDNEYVILLE_RET_65171204	1	2.00	2.00	104.85	1/8/2021 6:00 PM
20	257688989	Overhead By Phase	ABC	224.0 A	EDNEYVILLE_RET_65171204	1	2.00	2.00	104.85	1/8/2021 6:00 PM
21	257688994	Overhead By Phase	ABC	224.0 A	EDNEYVILLE_RET_65171204	1	2.00	2.00	104.85	1/8/2021 6:00 PM
22	250512550	Overboad By Bhase	C	170 O A	EDNEVITLE DET 25171204	7	2 00	2 00	105.24	1/0/2021 11:00 AM



Load Flow w/ Profiles Results After LRO







Eaton.com